



CHESTER P. VOISIN  
*President*  
JOHN PIZZOLATTO  
*Vice-President*  
CLIFTON J. STOUFFLET  
*Secretary*

STEPHEN HORNSBY  
VINCENT CELESTIN  
CHARLES BROWN, SR.  
RICHARD BAZET, JR.  
TERI CHATAGNIER  
WILBERT THOMAS

P.O. Box 630 • Houma, LA 70361  
Tel: (985) 879-2495 • Fax: (985) 879-2283  
[www.tpcw.org](http://www.tpcw.org)

MICHAEL A. SOBERT  
*General Manager*

CECILIA PRADO NORMAN  
*Chief Administrative Officer*

September 3, 2020

## Boil Water Advisory Cancelled

In accordance with Louisiana State Sanitary Code and the concurrence of the Louisiana Department of Health, the Boil Water Advisory issued on September 1, 2020 for customers located from 8121 up to and including 8151 Hwy 56, Crab and Hagedwood Court and Pier 1, Pier 4, Pier 5, Pier 56 has been lifted. Water Samples taken on Wednesday, 09/02/20, were tested and all tested negative for any bacteria. The water is safe for human consumption

Sample Location ID 1109002	Date	Chlorine Residual mg/L	Colilert P/A	Turbidity NTU
7713 Hwy 56; POC 205	09-02-20	1.60	A	0.66
8124 HWY 56	09-02-20	1.39	A	0.61
106 Pier 56 CT	09-02-20	1.11	A	0.69

It is no longer necessary to boil the water.

Michael A. Sobert  
General Manager